

October 20, 2003

CLEARSTREAM WASTEWATER SYSTEMS, INC.
JOHN BARNES / WAYNE PEYTON
PO BOX 7568
BEAUMONT TX 77709

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED
Manufacturer: CLEARSTREAM WASTEWATER SYSTEMS, INC.
Product Name: CLEARWATER WASTEWATER TREATMENT SYSTEM
Model Number(s): 750N (750 GPD)
Product File No: 20030471

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2008.

This approval supersedes the approval issued on October 9, 2001, under product file number 20010470.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010470.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 750 gallons per day.
- This product may not be installed more than 18 inches below final grade.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- A septic tank (pretreatment tank/trash trap) with a volume of at least 50% of the gallon per day rating of this product must be installed upstream of this product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov